


Address: 12345 Honeysuckle Lane

Smithville AR 72466

Home size: 2,800 square feet

Year built: 1970 Air conditioned: Yes



Top 20% of similarly sized homes score here or better



homeenergyscore.gov

The **Home Energy Score** is a national rating system developed by the U.S. Department of Energy. The **Score** reflects the energy efficiency of a home based on the home's structure and heating, cooling, and hot water systems. The **Home Facts** provide details about the current structure and systems. **Recommendations** show how to improve the energy efficiency of the home to achieve a higher score and save money.

Assessment date: 01/12/2012

Scored in: **2012** Score ID: **1913375**

Qualified assessor #: 101019

Score Home Facts Recommendations



About this home

Assessment date	01/12/2012
Address	12345 Honeysuckle Lane
City, state, zip	Smithville AR 72466
Year built	1970
Number of bedrooms	4
Stories above ground level	2
Interior floor-to-ceiling height (feet)	8
Conditioned floor area (all stories combined, square feet)	2,800
Direction faced by front of house	North



Estimated energy use per year

Total energy (MBTUs)	228
Electricity (kWh)	8,430
Natural gas (therms)	1,210
Oil (gallons)	0
Propane (gallons)	0



Comments

Score ID: **123456789** homeenergyscore.gov

Score Home Facts Recommendations



Air-tightness

Air leakage rate 3,800 CFM50



Roof, attic & foundation

Roof (standard roof) composition shingles or metal, R-0	
0.8	
Unconditioned attic	
R-19	



Foundation type

Floor insulation above basement or crawl space

Foundation walls insulation level

R-0



Wall construction

Front (or all sides same) Wood frame vinyl siding, R-11



Windows & skylights

Skylights	
Does the house have skylights?	No
Windows	
Window area front (square feet)	95
Window area right (square feet)	50
Window area back (square feet)	125
Window area left (square feet)	40
Are the window types the same on all sides?	Yes
Window type front (or all sides same)	Double-pane aluminum with thermal break clear

Score ID: **123456789** homeenergyscore.gov

Score Home Facts Recommendations



Systems

Cystems				
Heating system				
Туре	Central gas furnace			
Efficiency value	80.0 AFUE			
Cooling system				
Туре	Central air conditioner			
Efficiency value	12.0 SEER			
Ducts				
Duct location	Vented crawlspace			
Are the ducts insulated?	Yes			
Are the ducts sealed?	No/don't know			
Hot water system				
Fuel	Piped natural gas			
Efficiency value	0.59 EF			

For more information on calculation methods, technical terms and units of measure, please visit **homeenergyscore.gov**

Score Home Facts Recommendations

Address: 12345 Honeysuckle Lane

Smithville AR 72466

Repair now: These improvements will save you money, conserve energy, and improve your comfort now	Estimated utility bill savings (\$/year)
Ducts: Have your ducts professionally sealed to reduce leakage	\$140
Air tightness: Have a professional seal the gaps and cracks that leak	\$110
Basement/crawlspace: Insulate the floor above unconditioned space to at least R-38	\$50
Replace later: These improvements will help you save energy when it's time to replace or upgrade	Estimated utility bill savings (\$/year)

Replace later: These improvements will help you save energy when it's time to replace or upgrade	Estimated utility bill savings (\$/year)	
Water heater: Pick one with an ENERGY STAR label	\$50	
Furnace: Pick one with an ENERGY STAR label	\$150	

